

**Public Service Company of Colorado Transmission Provider
TTC Narratives**

Additional narrative information concerning ATC changes as the result of TTC changes can be found on the PSCo OASIS Home page under the "Outages" folder and on the PSCo OASIS Home page under the "Security" menu.

Time of Message	Event	Path	Increment	Class	Narrative
7/25/2007 13:00	TTC changed by 10% or more	W/PSCo/D/LAMR345-LAMR230/			E to W DC Tie Transfer Limited to 165 MW from 05/17/2007 14:00 to 05/18/2008 08:00 MPT
10/30/2007 10:00	TTC changed by 10% or more	W/PSCo//STY-PSCo/			Story to PSCo rating Limited to 478 MW due to limiting components associated with the line
10/30/2007 10:00	TTC changed by 10% or more	W/PSCo//PSCo-STY/			PSCo to Story rating Limited to 478 MW due to limiting components associated with the line
12/12/2007 13:00	TTC changed by 10% or more	W/PSCo/D/LAMR345-LAMR230/			E to W DC Tie Transfer Limit increased to the rated capacity of 210 MW 12/12/2007 01:00 MPT
6/1/2008 0:00	TTC changed by 10% or more	W/PSCo//STY-PSCo/			Story to PSCo rating Limited to 662 MW due to limiting components associated with the line
6/1/2008 0:00	TTC changed by 10% or more	W/PSCo//PSCo-STY/			PSCo to Story rating Limited to 662 MW due to limiting components associated with the line
8/19/2008 0:00	TTC changed by 10% or more	W/PSCo//LAMR230-MIDW/			LAMR230-MIDW Rating changed to 196 MW due to new transmission studies
7/29/2009 8:00	TTC changed by 10% or more	W/PSCo//PSCo-AU/			PSCo to Ault Rating changed to 884 MW due to new transmission studies
1/14/2010 0:00	TTC changed by 10% or more	W/PSCo//PSCo-PAWN/			PSCo to Pawnee Rating changed to 1300 MW due to system upgrades
1/14/2010 0:00	TTC changed by 10% or more	W/PSCo//PAWN-PSCo/			Pawnee to PSCo Rating changed to 1300 MW due to system upgrades
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//COMA-MIDW/			Comanche to Midway Rating changed to 1320 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//MIDW-COMA/			Midway to Comanche Rating changed to 1320 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//COMA-PSCo/			Comanche to PSCo Rating changed to 3432 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//PSCo-COMA/			PSCo to Comanche Rating changed to 3432 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//MIDW-BOON/			Midway to Boone Rating changed to 814 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//BOON-MIDW/			Boone to Midway Rating changed to 814 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//MIDW-FULLER/			Midway to Fuller Rating changed to 1042 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//FULLER-MIDW/			Fuller to Midway Rating changed to 1042 MW due to system upgrades and changing how the PSCo southern system is posted
5/28/2010 18:00	TTC changed by 10% or more	W/PSCo//PSCo-AU/			PSCo to Ault Rating changed to 516 MW to reflect only PSCo transmission rights
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//ATL-RFL/			Atlas to Rifle Rating changed to 86 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//BLUE-PSCo/			Blue River to PSCo Rating changed to 354 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//BOON-LAMR230/			Boone to Lamar 230 Rating changed to 210 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//BOON-MIDW/			Boone to Midway Rating changed to 271 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//COLL-RIFL/			Collbran to Rifle Rating changed to 25 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//COMA-MIDW/			Comanche to Midway Rating changed to 674 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//COMA-PSCo/			Comanche to PSCo Rating changed to 1333 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//CRG-HDN/			Craig to Hayden Rating changed to 496 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//FLUP-PSCo/			Fort Lupton to PSCo Rating changed to 279 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//FULLER-MIDW/			Fuller to Midway Rating changed to 377 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//FVAL-MIDW/			Fountain Valley to Midway Rating changed to 258 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//HDN-CRG/			Hayden to Craig Rating changed to 496 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//HDN-TOT5W/			Hayden to TOT 5W Rating changed to 476 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//KEEN-PSCo/			Keenesburg to PSCo Rating changed to 550 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//MALTA-PSCo/			Malta to PSCo Rating changed to 274 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCo//MALTA-SLVA/			Malta to San Luis Valley Rating changed to 60 MW to reflect new NERC MOD-029 standard studies

**Public Service Company of Colorado Transmission Provider
TTC Narratives**

Additional narrative information concerning ATC changes as the result of TTC changes can be found on the PSCo OASIS Home page under the "Outages" folder and on the PSCo OASIS Home page under the "Security" menu.

Time of Message	Event	Path	Increment	Class	Narative
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//MIDW-BOON/			Midway to Boone Rating changed to 271 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//MIDW-COMA/			Midway to Comanche Rating changed to 674 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//MIDW-FULLER/			Midway to Fuller Rating changed to 377 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PAWN-PSCO/			Pawnee to PSCO Rating changed to 871 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PAWN-STY/			Pawnee to Story Rating changed to 498 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-BLUE/			PSCO to Blue River Rating changed to 354 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-COMA/			PSCO to Comanche Rating changed to 1333 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-MALTA/			PSCO to Malta Rating changed to 274 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-PAWN/			PSCO to Pawnee Rating changed to 871 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-STVRN/			MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-TOT5E/			PSCO to Comanche Rating changed to 480 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//RFL-GJCT/			Rifle to Grand Junction Rating changed to 410 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//RFL-TOT2AN/			Rifle to TOT 2AN Rating changed to 135 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//RFL-TOT5W/			Rifle to TOT 5W Rating changed to 480 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//SJ345-TOT2AN/			San Juan 345 to TOT 2AN Rating changed to 200 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//STVRN-PSCO/			MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//STY-PAWN/			Story to Pawnee Rating changed to 498 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//TOT2AN-RFL/			TOT 2AN to Rifle Rating changed to 200 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//TOT2AS-SJ345/			TOT 2AS to San Juan 345 Rating changed to 60 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//TOT5E-PSCO/			TOT 5E to PSCO Rating changed to 480 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//TOT5W-HDN/			TOT 5W to Hayden Rating changed to 476 MW to reflect new NERC MOD-029 standard studies
4/1/2011 0:00	TTC changed by 10% or more	W/PSCO//TOT5W-RFL/			TOT 5W to Rifle Rating changed to 480 MW to reflect new NERC MOD-029 standard studies
2/9/2012 8:30	TTC changed by 10% or more	W/PSCO//LAMR230-BOON/			LAMR230-BOON Rating changed to 248 MW to reflect increase of 52 MW from 110 Agreement
5/23/2011 0:00	TTC changed by 10% or more	W/PSCO//PAWN-STY/			PAWN to STY rating changed to 613 MW to reflect revised NERC MOD-029 TTC study results.
5/23/2011 0:00	TTC changed by 10% or more	W/PSCO//STY-PAWN/			STY to PAWN rating changed to 613 MW to reflect revised NERC MOD-029 TTC study results.
5/23/2011 0:00	TTC changed by 10% or more	W/PSCO//PSCO-PAWN/			PSCO to PAWN rating changed to 1986 MW to reflect revised NERC MOD-029 TTC study results.
5/23/2011 0:00	TTC changed by 10% or more	W/PSCO//PAWN-PSCO/			PAWN to PSCO rating changed to 1986 MW to reflect revised NERC MOD-029 TTC study results.
5/23/2011 0:00	TTC changed by 10% or more	W/PSCO//COMA-PSCO/			COMA to PSCO rating changed to 3428 MW to reflect revised NERC MOD-029 TTC study results.
9/1/2012 0:00	TTC changed by 10% or more	W/PSCO//PSCO-TOT5E/			PSCO to TOT5 E rating changed due to WAPA TOT5 E-W study results. PSCo share decreased from 480 MW to 388 MW.
9/1/2012 0:00	TTC changed by 10% or more	W/PSCO//TOT5E-TOT5W/			TOT5 E to TOT5W rating changed due to WAPA TOT5 E-W study results. PSCo share decreased from 480 MW to 388 MW.
9/1/2012 0:00	TTC changed by 10% or more	W/PSCO//TOT5W-RFL/			TOT5W to RFL rating changed due to WAPA TOT5 E-W study results. PSCo share decreased from 480 MW to 388 MW.