
Xcel Energy North Control Center Daily Operations Report

Date: 5/9/2010

Out Time: In Time:
(Begin:) (End:)

6:55		Split Rock 5X36 115KV BKR out to add gas.
7:10	7:10	Elm Creek-Osseo-West Coon Rapids 115KV line tripped and reclosed auto.
		Momentary outage to Hennepin (GRE) and Osseo. Cause: Osseo TR1 13.8KV BKR failed.
9:54		Woodbury 5P174 115KV BKR out to add gas.