
Xcel Energy North Control Center Daily Operations Report

Date: 5/12/2010

Out Time: In Time:
(Begin:) (End:)

6:05	10:41	Wilmarth 5S17 115KV BKR out for maintenance.
6:15	11:46	Wilmarth 8S22 345KV BKR out for maintenance.
7:07	17:40	Arden Hills-Arsenal-St Croix Falls-Lindstrom 69KV line on non-reclose for GRE construction.
7:07	18:21	Apple River (DPC)-St. Croix Falls 69KV line on non-reclose for hot line work for DPC.
7:14		Paynesville-Roscoe 69KV line out for construction.
7:22	16:40	West Sioux Falls 5X42 115KV BKR out for maintenance.
7:24	15:45	Maple River 5F2 115KV BKR out for maintenance.
7:33	7:50	Sioux Falls-South Sioux Falls-West Sioux Falls 69KV line 97P and TN TT relaying out for maintenance.
7:44	11:17	St. Louis Park 5M89 115KV BKR out for maintenance.
7:50	8:04	Sioux Falls-South Sioux Falls-West Sioux Falls 69KV line 97S relay switch off for maintenance.
7:57	15:09	Parkers Lake 5M62 115KV BKR out for maintenance.
8:00	11:31	Rogers Lake 5P60 115KV BKR out for maintenance.
8:02		Lakefield-Fieldon-Wilmarth 345KV line CR PR, CR TT relaying and Wilmarth 97P relay switch off for maintenance.
8:11	18:56	Split Rock-West Sioux Falls 115KV line 97S relay switch off at West Sioux Falls off for maintenance.
8:45		Monticello TR10 B 13.8KV AUX TR out to perform Delta cable testing.
9:04	14:09	Pathfinder-Pipestone 115KV line CR PR, CR TT relaying and Pipestone 97P relay switch off for maintenance.
	9:24	Split Rock 5X36 115KV BKR, out since 05/10/10 to add gas, returned to service.

Xcel Energy North Control Center Daily Operations Report

Date: 5/12/2010

Out Time: In Time:
(Begin:) (End:)

9:26 13:50 Prairie Island generator 2 97P relay switch off for maintenance.

9:39 10:17 Chemolite-LS Power 115KV line watt-hour meter out for calibration.

9:46 Pipestone 5X777 115KV BKR, out since 05/11/10 for maintenance, returned to service.

10:09 15:28 Red Rock 969 115KV BKR out for maintenance.

10:41 11:24 Wilmarth 5S18 115KV BKR out for maintenance.

10:55 Elk River(GRE)-Monticello 230KV line 97P relay switch off at Monticello for maintenance.

10:58 Loyal-DPC Loyal-Grassland 69KV line out for DPC work.

11:00 21:00 Time correction "G" in effect. Time was fast.

11:18 12:16 St. Louis Park 5M95 115KV BKR out for maintenance.

11:26 Wilmarth 5S8 115KV BKR out for maintenance.

11:33 16:00 Rogers Lake 5P61 115KV BKR out for maintenance.

12:03 Wheaton 161/13.8KV TR1 held out for control cable and power cable replacement.

12:45 Sauk River-St. Cloud 115KV line, out since 04/08/10 for construction, released.

13:00 Sauk River-St. Cloud 115KV line, out since 04/08/10 for construction, phase-checked and returned to service

13:43 Colvill 115/69KV TR4 held out for construction.

13:50 16:20 Prairie Island generator 2 97S relay switch off for maintenance.

14:10 16:57 Pathfinder-Pipestone 115KV line 97S relay switch off at Pipestone for maintenance.

14:24 Colvill 115KV bus 2 and 161/115KV TR5, out since 05/03/10 for construction, returned to service.

Xcel Energy North Control Center Daily Operations Report

Date: **5/12/2010**

Out Time: *In Time:*
(Begin:) *(End:)*

- 15:23 Hydro Lane-Wheaton 161KV line, out since 5/3/2010, returned to service.
- 15:54 King-Eau Claire 345KV line on non-reclose since 05/10/10 for hot line work, returned to normal.
- 15:54 Arpin (ALT)-Eau Claire 345KV line on non-reclose since 05/10/10 for hot line work, returned to normal.