
Xcel Energy North Control Center Daily Operations Report

Date: 5/14/2010

Out Time: In Time:
(Begin:) (End:)

0:00	17:18	MISO requested curtailments at Mower County Wind remain in effect. Maximum output of 22MW per the Adams-Rochester 161KV Operating Guide.
6:25	10:23	Sheyenne 5F28 115KV breaker out for maintenance.
8:07	12:52	Burnsville 115/69KV TR 6 out for GRE maintenance.
8:12	14:25	Hydro Lane 161/115KV TR 6 out for maintenance.
8:19		Pine Lake-Willow River 115KV line 97/67-GP, 97/21-68, and 283P relay switches off for construction.
8:26		Lindstrom 5P285 115KV MOD disengaged and secured open for construction.
8:44	14:07	Black Dog 115KV bus 3 out for maintenance.
9:06	13:12	Stone Lake 6R1 161KV BKR out for maintenance.
9:06	15:02	Yankee 322 and 321 34.5KV feeders out for customer maintenance.
9:25	10:40	Lake Yankton 115/34.5KV SVC out for maintenance.
9:40	12:01	Lakefield Junction(ITC)-Lakefield 345KV line out for house move.
	9:55	Sheyenne 115KV cap 4 BKR, out since 04/23/10 for repair, returned to service.
	11:49	Chisago County-Lindstrom 69KV line and Chisago 115KV bus, held out since 05/03/10 for construction, released for commissioning.
	11:49	Chisago County-Lindstrom 69KV line and Chisago 115KV bus, held out since 05/03/10 for construction, released for commissioning.
	11:49	Lindstrom 5P284, 5P285 and 5P286 115KV MOD's, disengaged since 04/23/10 for construction, released for commissioning.

Xcel Energy North Control Center Daily Operations Report

Date: 5/14/2010

Out Time: In Time:
(Begin:) (End:)

- 14:36** Paynesville-Roscoe 69KV line, out since 05/12/10 for construction, returned to service.
- 14:42** **15:57** Lakefield Junction-Jackson North 161KV line out for house move.
- 16:54** Monticello TR 10 Station Aux B 13.8KV fused disconnect, out since 05/12/10 for plant maintenance, returned to service.