

---

---

# ***Xcel Energy North Control Center Daily Operations Report***

***Date: 7/5/2010***

---

---

***Out Time: In Time:***  
***(Begin:) (End:)***

**8:09 22:54** Black Dog 5M260 and 5M262 115KV OCB's open to split ring bus per operating procedure.

**14:46** West Waconia -St. Bonifacious 115KV line CR TT control turned off for circuit trouble.

**16:00 23:30** MISO/XCEL has issued a NERC TLR level 3A on the MWEX, flowgate 6193.

**17:07 17:07** Lincoln County 5X6 and 5X4 115KV breakers tripped and reclosed auto. Lincoln County 115/13.8KV TR7 tripped and locked out.

Momentary outage to Lincoln County 13.8KV bus 1.

TR7 remains out for inspection.

**20:22 20:22** Hutchinson (GRE)-Victor (GRE) 69KV line tripped and reclosed auto.

Momentary outage to Lake Jennie (GRE), Hook Lake (McLeod).

Cause of trip: storm.