
Xcel Energy North Control Center Daily Operations Report

Date: **7/22/2010**

Out Time: *In Time:*
(Begin:) *(End:)*

4:58	15:08	Byron-Prairie Island 345KV line CR TT relaying off at Byron for circuit trouble.
5:25	13:44	Coon Creek-Sherburne County #3 345KV line TN PR and TN TT relaying off due to circuit trouble.
6:37	23:21	Black Dog 5M260 and 5M262 115KV OCB's open to split ring bus per operating procedure.
8:01		Granite City-St. Regis 115KV line on non-reclose for hot line work.
8:21	19:09	Dell Rapids-Pipestone 69KV line out for maintenance.
	10:19	Eagle Lake (GRE)-Wilmarth 69KV line, out since 07/19/10 for maintenance, returned to service.
10:22		Colvill 115KV bus 2 out for maintenance.
	10:26	Arlington 4S199 69KV breaker, open for area protection since 07/19/10, closed.
	10:26	Cleveland 4S100 69KV BKR, open since 07/19/10 for area protection, closed.
10:50	14:40	Grant 115KV auto sectionalizing control on manual for relay maintenance.
10:57		Colvill 115/161KV TR4 A disconnect further held for construction.
	11:25	DPC Cashton Tap-Westby Tap 69KV line section, out since 07/19/2010 for structure maintenance, returned to service.
	11:53	Long Prairie 867L 115KV BKR, open since 07/20/2010 for MP work, returned to normal.
	12:34	Parkers Lake 5M48 115KV BKR, out since 07/13/10 for substation training, returned to service.
	13:20	Carver County TR 1 69KV breaker, out since 07/22/10 due to low gas, returned to service.

Xcel Energy North Control Center Daily Operations Report

Date: 7/22/2010

Out Time: In Time:
(Begin:) (End:)

- 14:19** MISO is declaring a Hot Weather Alert, effective 0700 07/23/10 EST to 2200 07/23/10 EST, for the MISO Footprint. Average temp is expected to be 91 degrees.
- 17:12** Emerado (MPC)-Prairie (MPC) 69KV line, out since 07/19/2010 for maintenance, returned to service.
- 18:35** West Pipestone 4X750 69KV BKR out for replacement
- 18:42** West Pipestone 4X10 LI SW open for relay protection.
- 20:00** Lake Yankton 115KV CAP 4 out since 07/20/2010 for maintenance, returned to service.