

---

---

## ***Xcel Energy North Control Center Daily Operations Report***

---

---

**Date: 2/3/2012 11:59:09 PM**

---

---

**Out Time: In Time:**  
**(Begin:) (End:)**

<b>6:34</b>		<b>Ironwood-Gogebic-Mine Road 88KV line on non-reclose for maintenance.</b>
<b>7:35</b>	<b>14:30</b>	<b>Chisago County 115KV 97/87B2S relay switch off for maintenance.</b>
<b>7:43</b>	<b>14:31</b>	<b>GRE Rush River-GRE New Sweden 69KV line out for maintenance.</b>
<b>8:12</b>	<b>15:09</b>	<b>Aldrich-West River Road #2 115KV line TN PR and TN TT and 97P relay switches off at both ends for maintenance.</b>
<b>8:25</b>	<b>14:52</b>	<b>Coon Creek-West Coon Rapids 115KV line TN PR and TN TT and 97P relay switches off at both ends for maintenance.</b>
<b>8:47</b>	<b>14:57</b>	<b>Marshland 4L18 69KV BKR held out for repair.</b>
<b>8:55</b>	<b>13:54</b>	<b>Seven Mile 4E209 69KV BKR out for maintenance.</b>
<b>8:55</b>	<b>9:30</b>	<b>Jackson County-Melrose Switching Station 69KV line non-reclose for construction.</b>
	<b>9:02</b>	<b>Chemolite 5P128 115KV BKR, out since 02/02/12 for maintenance, returned to service.</b>
<b>9:03</b>	<b>14:45</b>	<b>Chemolite 5P134 115KV BKR out for maintenance.</b>
<b>9:36</b>	<b>11:45</b>	<b>GRE St. Bonifacius 4M24 69KV BKR out for GRE maintenance. Waconia 9 N.O. 69KV MOD closed for this work.</b>
	<b>9:39</b>	<b>Melrose Switching Station-DPC Shamrock 69KV line, out since 01/17/12 for construction, returned to service.</b>
	<b>11:23</b>	<b>Wakefield 115KV bus 1, out since 02/02/12 for maintenance, returned to service.</b>
<b>12:00</b>		<b>Time correction "B" in effect. Time was fast.</b>
	<b>12:57</b>	<b>Crossroads-MEI International 115KV line, out since 01/23/12 for construction, returned to service.</b>

---

---

## ***Xcel Energy North Control Center Daily Operations Report***

***Date: 2/3/2012 11:59:09 PM***

---

---

***Out Time: In Time:***  
***(Begin:) (End:)***

- 13:37 Wescott-GRE Wescott Park 69KV line, out since 02/02/12 for construction, returned to service. Wescott Park C550 N.O. 69KV MOD returned to normal.
- 13:47 Catawba-Prentice 115KV line, out since 01/31/12 for construction, returned to service.
- 13:56 14:33 Cherry Creek 5X66 115KV BKR out for maintenance.
- 14:31 South Bend-GRE Century 69KV line, out since 01/03/12 for construction, returned to service.
- 15:41 DPC Glenmont-Red Rock 115KV line, out since 01/30/12 for XCEL-W maintenance, returned to service.
- 16:20 Red Rock-DPC Glenmont Tap 115KV line, out since 01/30/12 for construction, returned to service.