

**Public Service Company of Colorado Transmission Provider
TTC Narratives**

Additional narrative information concerning ATC changes as the result of TTC changes can be found on the PSCo OASIS Home page under the "Outages" folder and on the PSCo OASIS Home page under the "Security" menu.

Time of Message	Event	Path	Increment	Class	Narative
7/25/2007 13:00	TTC changed by 10% or more	W/PSCO/D/LAMR345-LAMR230/			E to W DC Tie Transfer Limited to 165 MW from 05/17/2007 14:00 to 05/18/2008 08:00
10/30/2007 10:00	TTC changed by 10% or more	W/PSCO//STY-PSCO/			Story to PSCo rating Limited to 478 MW due to limiting components associated with the line
10/30/2007 10:00	TTC changed by 10% or more	W/PSCO//PSCO-STY/			PSCo to Story rating Limited to 478 MW due to limiting components associated with the line
12/12/2007 13:00	TTC changed by 10% or more	W/PSCO/D/LAMR345-LAMR230/			E to W DC Tie Transfer Limit increased to the rated capacity of 210 MW 12/12/2007 01:00
6/1/2008 0:00	TTC changed by 10% or more	W/PSCO//STY-PSCO/			Story to PSCo rating Limited to 662 MW due to limiting components associated with the line
6/1/2008 0:00	TTC changed by 10% or more	W/PSCO//PSCO-STY/			PSCo to Story rating Limited to 662 MW due to limiting components associated with the line
8/19/2008 0:00	TTC changed by 10% or more	W/PSCO//LAMR230-MIDW/			LAMR230-MIDW Rating changed to 196 MW due to new transmission studies
7/29/2009 8:00	TTC changed by 10% or more	W/PSCO//PSCO-AU/			PSCo to Ault Rating changed to 884 MW due to new transmission studies
1/14/2010 0:00	TTC changed by 10% or more	W/PSCO//PSCO-PAWN/			PSCo to Pawnee Rating changed to 1300 MW due to system upgrades
1/14/2010 0:00	TTC changed by 10% or more	W/PSCO//PAWN-PSCO/			Pawnee to PSCo Rating changed to 1300 MW due to system upgrades