
Xcel Energy Control Center Daily Operations Report

Date: 5/3/2010

Out Time: In Time:
(Begin:) (End:)

8:43		9332 Arapahoe Sw. Yd. to Gray St. 115KV line CLNC, to replace tower.
8:52	11:38	Waterton #1 & #2 115kv bus, PERM to adjust gang switch
9:14		9335 Arapahoe Sw. Yd. to Bancroft 115KV line, CLNC to replace tower.
10:03	14:26	Daniels Park 5102 230kv PCB, CLNC to add oil