
Xcel Energy Control Center Daily Operations Report

Date: 6/30/2010

Out Time: ***In Time:***
(Begin:) ***(End:)***

5:22	17:32	5625 Denver Terminal to Elati 230KV line, CLNC for maintenace
6:11	17:50	5463 Ft. Lupton to Pawnee 230KV Line HLH for cross arm repair
11:49	17:45	5109 Daniels Park to Tarryall 230KV line, authorization to block Primary and BF relays at TARR
16:02	16:04	9257 Climax to Malta 115KV & 9254 Climax to Malta 115KV lines, trip and remained out

Outage: 2 Minute outage to Leadville, Climax, Summit, Mayflower, and Gilman

Cause: Unknown