
Xcel Energy Control Center Daily Operations Report

Date: 7/1/2010

Out Time: *In Time:*
(Begin:) *(End:)*

3:29	3:30	6683 pcb @ Uintah tripped. Cause: unsure Outage: 1 minute outage to Fruita.
5:34	17:49	Denver Terminal - Elati 230KV line, CLNC for Fast Tracks.
6:10	17:08	5463 Ft. Lupton to Pawnee 230KV, HLH to replace cross arms.
7:00	7:00	PSCo Transmission System Green
7:36	11:00	Cherokee East 115KV Bus rlys, pri and secondary blkd for maintenance
8:46	14:45	Daniels Park to Surry Ridge 230KV line, CLNC to repair switches.
9:02	10:48	Soda Lakes 8027 115KV PCB, PERM for testing.
9:48	10:50	Valmont Sw. Yd. 9066 115KV PCB, CLNC for repairs.
12:23	13:48	Soda Lakes 8028 115KV PCB, PERM for testing.
14:57	15:53	Soda Lakes #1 115KV bus, Emergency CLNC to remove jumpers from pot dev.

Overloaded Arapahoe - Bancroft 115KV Line then tripped
Causing the following outages @1537

South Bank #1	30 Mw
Bancroft Banks #1 and #2	70 Mw
Conifer(IREA)	10 Mw
Tiny Town	9 Mw
Allison	about 60 Mw
Kendrick	about 60 Mw

Tranmission was restored at 15:53 (Transmission Outage was 16 Minutes)

Xcel Energy Control Center Daily Operations Report

Date: 7/1/2010

Out Time: *In Time:*
(Begin:) *(End:)*

19:34 **6:42** Transmission dispatch has issued a reliability directive to PSCo energy markets to run all available Arapahoe generation due to transmission issue.

Transmission dispatch has released the reliability directive to PSCo Energy Markets @ the Arapahoe Generation Station @ 06:42 MDT on 07/02/2010.