

---

---

## *Xcel Energy Control Center Daily Operations Report*

---

---

*Date:* 7/23/2010

---

---

*Out Time:*   *In Time:*  
*(Begin:)*     *(End:)*

6:35	17:41	5185 Spruce to Tower 230KV line, CLNC for proximity work
6:58	17:31	5463 Ft. Lupton to Pawnee 230KV line, HLH to replace X-arms
8:19	15:46	5411 Comanche Sw. Yd. to Midway 230KV Line, CLNC to replace X-Arms
9:28	17:24	Daniels Park 7035 S & 7036 N Gang Switches, CLNC for maintenance.
10:26	14:43	Rosedale 9996 115kv PCB, PERM for CA
14:42	14:44	6935 Alamosa Plant to Mosca Jct. 69KV Line, tripped & reclosed

Cause: Weather in the area

Outage: None