
Xcel Energy Control Center Daily Operations Report

Date: 7/26/2010

Out Time: *In Time:*
(Begin:) *(End:)*

5:30	17:30	SHIFT CHANGE: NRL: Zehr/TSO: Gruesner/BAO: Martinez
5:46	13:18	9544 East to FITZ 115KV line, CLNC to perform bridge work.
5:49	18:12	5463 Ft. Lupton to Pawnee 230KV Line, HLH for crews in proximity.
5:53	13:20	9543 East to Hava 115KV line, CLNC to perform bridge work
6:55	18:07	5185 Spruce to Tower 230KV Line, CLNC for crews in proximity.
7:00	7:00	PSCo Transmission System Green
8:32	15:59	5411 Comanche Sw. Yd. to Midway 230KV Line, CLNC to repair X-arms.
12:36	15:16	Eldorado Springs 9688 115KV PCB, PERM to replace trip coil
13:00	21:00	PSCo Transmission System Yellow due to high loads.
14:03		9256 Hopkins to Basalt 115KV Line, CLNC to replace wave trap @ BASA.