
Xcel Energy Control Center Daily Operations Report

Date: 1/22/2012

Out Time: In Time:
(Begin:) (End:)

**2:28 2:28 8416 Wolcott to Vail 115KV, tripped and reclosed
automatically from the Wolcott end but not at the Vail end.**

Cause: Snow storm in the area

Outage: No Load Lost