

---

---

# *Xcel Energy South Control Center Daily Operations Report*

*Date:* 8/3/2008

---

---

**Out Time:** *In Time:*  
**(Begin:)** **(End:)**

<b>1:32</b>		N/S flow staying around 850. Ace -2 and units on deployment number. Have 443mw of wind. SPP RC lowered setpoint to 770.
	<b>5:00</b>	TEC "B" ended. Frequency returned to 60Hz.
<b>10:05</b>	<b>12:28</b>	SPP issued TLR 3B on imports SPP released TLR to zero
<b>10:06</b>		SPP issued TLR 3B on SPP/SPS Import Tie.
<b>13:18</b>	<b>21:22</b>	Cunningham Sta - unit #4 online for reliability (Trans oper). Offline per XEM.
	<b>13:33</b>	SPP released TLR on N/S flow to zero
<b>15:00</b>		Notified S.O.C - The system condition changed from Green to Yellow due to high load and generation shortage
<b>22:20</b>		N/S flow coming up. Called for TLR 3B