
Xcel Energy South Control Center Daily Operations Report

Date: 8/7/2008

Out Time: *In Time:*
(Begin:) *(End:)*

0:28	6:50	SPP issued a 3B TLR on the N/S. SPP released TLR to zero
2:01	3:02	Eddy Co HVDC - Tie online for 1 hour schedule.
	03:02	- Tie offline; no schedules. When taking the tie offline, 4K47 and 4R01 (capacitor breakers) tripped offline. The tie did not trip and came offline normally by control, but the capacitors did trip. Will notify morning dispatchers to get someone out this morning before tie is scheduled to come back online.
5:39	6:00	Plant X Sta - Change 100 amp breaker out on fan.
6:34	16:46	Terry Co Interchange - wiring behind the panels and pulling wire
7:43	19:31	Tuco Interchange North 230/115KV TR - install fans and stack the TR.
8:21	15:04	Sundown Interchange to Terry Co Interchange V55 - H/L TWR change arms.
8:30		69KV Ckt Z25 from Sw 6706 to Sw 6707 out to change arms.
9:22		Shell CO2 - take out N 115/12.5KV TR
9:33		Cunningham Sta Unit #3 on line for reliability for resources
10:25		Load Shed Notification
10:31	16:54	Deaf Smith Co Interchange - Test relays
10:38		Cunningham Sta Unit #4 on line for reliability for resources
10:38	23:09	Cunningham Sta Unit #4 on line for reliability for resources
	10:56	Cox Interchange to Floyd Co Interchange Y77 - wreck out old Y77 and rebuild Y77/T81 line.
		Released and Terminated
11:24	16:33	Moore Co Interchange - test relays

Xcel Energy South Control Center Daily Operations Report

Date: 8/7/2008

Out Time: *In Time:*
(Begin:) *(End:)*

11:57 Nichols Sta 115KV BKR B988 back in service

12:00 Notified S.O.C - The system condition changed from Green to Yellow due to high load

13:29 Indiana - Doble-CA-Overhaul Mech.

Released and terminated

16:58 19:52 Grapevine Interchange to PSO - Elk City K54. PSO requested we open our BKR 2K70 at Grapevine to take line out of service. A contractor hit a gas line underneath the line at Elk City.
PSO requested BKR 2K70 closed at Grapevine.

23:37 SPP issued a 3B TLR on the N/S.