

---

---

# *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date: 8/10/2008*

---

---

*Out Time: In Time:*  
*(Begin:) (End:)*

1:10		TLR 3B on N/S flow.
2:00		Eddy Co HVDC is offline, no schedules.
8:30		Tuco Interchange  Stack Transformer & Pull vacuum
13:02		Cunningham Sta # 3 on line for voltage support.
15:02	15:27	Frankford to Murphy- dead line clearance to clear plastic on trans. line
17:49	17:49	Crosby Co Interchange to Lubbock East Intg T69- 115KV. Bkr 9980 @ Crosby Co. operated one time and closed. Bkr 6915 @ Lubbock East operated and closed at the same time. Fault distance from Crosby Co. 18.5 mi. Fault distance from Lubbock East 6.1 mi Storms in area.
18:35		Cochran Co Interchange to Sundown REC Z20- 69KV. Bkr 7840 operated twice and locked out @1835. Affecting Lyn-REC at Sundown. Attempted to reclose bkr 7840 @ 1859 after verification from Lyn-REC. bkr 7840 opened back. Lyntegar EC has Sundown backfed. Storms in Area.
19:17	23:41	Brownfield to Seagraves/Sulphur Springs Intg Z46 - 69 KV Bkr 6F30 at Sulphur O/C/O/C/O @ 1917. Closed bkr 6F30 by SCADA and it tripped. Report of poles down 6 1/2 mi E. of Wellman on FM213.  Poles down on Lyn REC Foster sub tap. Opened switch AB110 at tap to isolate. Closed bkr 6F30 at 23:41 restoring service to Union Texas sub Storms in Area.

---

---

## *Xcel Energy South Control Center Daily Operations Report*

*Date: 8/10/2008*

---

---

**Out Time: In Time:**  
**(Begin:) (End:)**

- 19:17 23:41 Sulphur Springs Interchange-69KV bkr 6F30 at Sulphur Springs O/C/O/C/O at 1917. Attempted to reclose @ 1920 and locked out. This affect Lyn-REC Foster and Union Texas sub. Lyntegar EC has trans. Poles down north of their switch AB160. AB160 is open. Patrolman looking at the rest of the line. Nothing found. Reclosed 6F30 @ 2341  
Storms in area.
- 19:25 20:53 Seagraves Interchange to Sulphur Springs Intg T20- 115 KV bkr 6H65 O/C/O @ 1925 at Sulphur Springs. 115 KV bkr 6H55 O/C/O/C/O at Seagraves Intg. At the same time. Reclosed 6H55 @ 2053. Reclosed 6H54 @ 2054.  
Storms in Area.
- 19:59 20:09 Higgs to Hobbs Gen T98 Shell CO2 GCP to Yoakum Co Interchange V49-115 KV. Bkr 6H05 operated to lockout. Reclosed bkr 6H05 @ 2009.  
Storms in Area.
- 19:59 20:06 Higgs- 115KV. Bkr 4H165 & 4H170 opened @ 1959. Reclosed 4H165 @ 2006 and reclosed 4H170 @ 2007.  
Storms in area.
- 20:00 20:12 Denver City Interchange to Shell CO2 GCP V95 - 115KV bkr W980 O/C opened @ 2000. (This happened one minute after 6H05 opened @ Yoakum) reclosed and held @2012  
Storms in Area.
- Fault location is .8 miles from Denver City.
- 22:51 22:51 Brownfield Sw Sta to Lynn Co Interchange Z53 - Lynn breaker 7760 operated one time. Storms are in the area. No fault location data available.
- 23:00 23:21 Tested Carriers