
Xcel Energy South Control Center Daily Operations Report

Date: 8/16/2008

Out Time: In Time:
(Begin:) (End:)

1:38 1:38 Artesia Interchange to Roswell Interchange Z08 - Bkr. 4720 @ Artesia O/C. One operation. Storms in the area. This affected Smith, Lake Arthur CVEC, Hagerman CVEC, and Cottonwood Sub's.

4:03 SPP issued a level 5 TLR for feasibility.

4:44 4:44 Brownfield to Seagraves/Sulphur Springs Intg Z46 - Bkr. 6F30 @ Sulphur Springs O/C. One operation. Storms in the area. Fault location is 2.6 Mi. from Sulphur Springs. Affected LYN-REC Foster and Union Sub's.

5:25 6:56 Jones Sta to LP & L (Holly) (*1) K26 - Bkr. JK50 @ Jones Opened. It appears that LPL has a total blackout. The remaining three feeds from us are energized and show no flow. Attempted to contact LPL to no avail. DDC reported a big outage within Lubbock. Waiting for LPL to patrol K26 before attempting to close.
Closed JK50 at Jones at 0656 at LP&L request.

Bordon Co Interchange to Grassland Interchange K48 - Bkr. 7H25 O/C @ Borden. One operation. Storms in the area, but this happened at the same time as LPL going in the dark.

5:28 SPP lowered the N/S TLR to a level 3.

8:04 10:08 Lea National to Maddox Sta V83 H/L reestablished for line maintenance.

8:15 N/S TLR 3A released to 0

Import tie TLR 3A released to 0

13:10 16:26 Import tie flow coming up. Called for TLR 3B
SWPP released TLR to zero

19:30 19:53 Tested carriers

20:13 Yoakum Co Interchange - SCADA indicated RTU down @ 1937. Called in to IOC Ticket #1818142

21:13 Start TEC "L" and regulate to 59.98hz

Xcel Energy South Control Center Daily Operations Report

Date: 8/16/2008

Out Time: *In Time:*
(Begin:) *(End:)*

21:42 23:21 SWPP issued TLR 3B on imports

TLR going to zero on the imports @ 2321

23:00 Eddy Co HVDC - off line no schedules.