
Xcel Energy South Control Center Daily Operations Report

Date: 8/18/2008

Out Time: *In Time:*
(Begin:) *(End:)*

2:00		Eddy Co HVDC - off line no schedules.
2:08	2:09	Potash Junction Interchange - Bkr. 4820 O/C/O/C. Two operations. Storms in the area. This affected Miss. Chemical.
7:56		Lea National to Maddox Sta V83 H/L reestablished for line maintenance.
8:50	9:19	Replacing a fan on the north UPS
9:26	16:27	Deaf Smith Co Interchange testing relays one at a time.
9:37		Amoco Sw Sta 230KV breaker 3K20 out for condition assessment dole test and overhaul mechanism.
9:47		Happy Interchange LTC back in auto.
11:40		San Juan Sw Sta to Wind Farm
12:58	14:43	Tolk Sta 230KV breaker TK09 bleeding air tank down and replacing a leaky gasket.
14:40	16:12	Hobb Generating Sta working in the RTU.
14:55	15:06	Eddy Co HVDC to Amrad - 345KV bkr, 4R05 opened @1455 and Tie tripped off line. EPE closed at Amrad. Restarted Tie @ 1506.
14:56	15:30	Taylor Sw Sta installing a battery trailer.
17:18		SWPP issued TLR 3B on imports
17:45	18:09	Carriers tested OK, except for the PCA carriers. The RTU is down at PCA.