
Xcel Energy South Control Center Daily Operations Report

Date: 8/24/2008

Out Time: *In Time:*
(Begin:) *(End:)*

0:39		SPP issued TLR 3A on N/S Flow.
	4:04	Eddy Co HVDC - Tie is off line, no schedules
8:26		TLR to "0" on N/S flow.
10:55		Eddy Co HVDC is online.
11:08	12:26	TLR 3B on SPP/SPS imports.
18:00		Carriers Tested. PCA RTU is down
22:35		SPP issued TLR 3B on SPP/SPS Import tie.
22:35		SPP issued TLR 3B on N/S Flow.