

---

---

# *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date:* 8/26/2008

---

---

*Out Time:* *In Time:*  
*(Begin:)* *(End:)*

|       |       |   |
|-------|-------|---|
| 2:05  |       | Eddy Co HVDC- Off line no schedules.  |
| 4:00  |       | End of TEC "N"  |
| 5:19  | 6:36  | Chaves Co Interchange- Low Operating Pressure Al.<br>DDC contacted to call out Sube @ 055<br>Alarm cleared.                 |
| 6:30  |       | TLR to "0" on SPP/SPS imports.  |
| 7:39  | 17:24 | Sundown Interchange to Terry Co Interchange V55 H/L<br>clearance established for line maintenance.                          |
| 8:11  | 20:34 | Lea National to Maddox Sta V83 H/L clearance reestablished<br>for line maintenance.<br><br>Temp. Release & Temp. Terminated |
| 8:56  | 15:30 | Terry Co Interchange wiring behind the panels.  |
| 9:00  |       | Eddy Co HVDC is online.   |
| 9:26  | 14:09 | Hansford Sw Sw to Texas Co Interchange T88 - H/L for<br>contractor to pull fiber optic over line.                           |
| 9:45  | 16:30 | Deaf Smith Co Interchange to Hereford Intg V51 - test pilot<br>wire   |
| 10:23 | 11:39 | Industrial - testing billing meters   |
| 10:39 |       | San Juan Sw Sta to Wind Farm - plug relays  |
| 10:51 | 17:57 | Hobb Generating Sta - comm circuits on various terminal equip   |
| 11:40 | 13:37 | Amoco Wasson - Unit tripped offline.<br><br>13:37 - Unit back online.   |
| 12:05 | 16:59 | PCA Interchange - Test CT's   |
| 13:48 |       | Hale Co Interchange - test relays one-at-a-time   |

---

---

# *Xcel Energy South Control Center Daily Operations Report*

*Date: 8/26/2008*

---

---

**Out Time: In Time:**  
**(Begin:) (End:)**

14:30 15:19 Cox Interchange to Floyd Co Interchange Y77 - install jumpers  
for the 20MVA mobile sub at LEC Aiken

17:13 18:37 Hobb Generating Sta - add nitrogen to one of the PT/CT

Released & Terminated

21:57 N/S flow coming up. Called for TLR 3A

23:06 4:46 Grapevine Interchange to PSO - Elk City K54- Transformer  
problems @ Elk City  
Bkrs 1301,1305 and MOD 2302 opened @ 2306.  
PSO Sube Bypassed Relay.  
PSO closed MOD 2302 at 0443.  
Closed 2K70 @ Grapevine @ 0446.  
PSO closed BKRS 1301 & 1305 at 0447.

23:17 1:19 Jericho WTU to Kirby Sw Sta T52 -Circuit Switcher 5157  
opened @ 2317  
WTU- Sube in Route  
WTU reset lockout, closed 5157 @ 0119