
Xcel Energy South Control Center Daily Operations Report

Date: 8/28/2008

Out Time: *In Time:*
(Begin:) *(End:)*

2:05 Eddy Co HVDC - Off line no schedules.

7:28 10:08 Sundown Interchange to Terry Co Interchange V55 H/L clearance reestablished for line maintenance.

8:01 16:17 Lea National to Maddox Sta V83 H/L clearance reestablished for line maintenance.

8:11 Nichols Sta - CA & Mechanism and overhaul 230KV BK20

8:26 SPP released the TLR on the N/S.

9:42 Hale Co Interchange testing relays

9:46 10:53 Roswell Interchange 69KV capacitor breaker out to repair hot spots on disconnect 4601.

10:01 Eddy Co HVDC - on line for schedules.

11:48 15:40 Grapevine Interchange 230KV BKR 2K70 - disable transfer trip.

14:24 SPP issued a 3B TLR on the imports.

18:32 20:07 Artesia Interchange to Roswell Interchange 69KV Ckt Z08 from Artesia to N.O. Sw.4744. 69kv Gcb 4720 opened,closed,open,closed,opened and locked out. Storms in area.
18:33 Tried Gcb 4720 @ Artesia one time and did not hold.
18:34 Opened Sw# 4788 @ Cottonwood tap by scada
18:35 Closed Gcb 4720 @ Artesia and it held. Power restored to Smith sub,Lake Arthur CVEC, Cottonwood Sub #1, Hagerman CVEC,
Cottonwood CVEC is only customer still out at this time.
Problems appear to be on CVEC tap. Will need targets on 69kv Gcb 4720 @ Artesia. Line patrol on Z8 from Artesia to N.O. Sw# 4744 may not be necessary with location of fault.
19:39 CVEC reports twister came through area and they have a pole down on Cottonwood Tap.
20:07 Per CVEC repairs complete. Sw# 4788 closed and CVEC Cottonwood restored.

Xcel Energy South Control Center Daily Operations Report

Date: 8/28/2008

Out Time: In Time:
(Begin:) (End:)

- 18:41** Hutchinson Co Interchange LOP Alarm on 115kv Ocb 1920
Multi breaker tripped on Air Compressor. Reset and back to normal.
Further repairs may be needed next week
- 20:12** **20:12** Pecos Sw Sta to Seven Rivers Interchange T62 115KV Gcb
3H195 @ Seven Rivers opened,closed,& 115kv Gcb 3H250 @
Pecos opened,closed
Blinked CVEC Cone Butte Seven. Storms in area. Fault locate
from Seven Rivers shows 17.4 miles.
- Will need targets on 115kv Gcb 3H195 @ Seven Rivers and
115kv Gcb 3H250 @ Pecos & line patrol on 115kv Ckt T62
Seven Rivers to Pecos.
- 20:13** **20:15** Pecos Sw Sta to Seven Rivers Interchange T62 115KV Gcb
3H195 @ Seven Rivers opened & locked out..& 115kv Gcb
3H250 @ Pecos opened,closed
Blinked CVEC Cone Butte Seven. Storms in area. Fault locate
from Seven Rivers shows 17.4 miles
20:15 115kv Gcb 3H195 @ Seven Rivers did not reclose on
operation. Closed by scada.
- Will need targets on 115kv Gcb 3H195 @ Seven Rivers and
115kv Gcb 3H250 @ Pecos & line patrol on 115kv Ckt T62
Seven Rivers to Pecos.