
Xcel Energy South Control Center Daily Operations Report

Date: 8/29/2008

Out Time: *In Time:*
(Begin:) *(End:)*

3:05 Eddy Co HVDC- Off line no schedules.

3:35 SWPP released TLR on imports

6:54 SPP issued a 3A TLR on the imports.

7:29 SPP released the TLR on the N/S.

8:57 Eddy Co HVDC - on line for schedules.

9:08 14:24 Hockley Co Interchange testing UFR - Also, testing the UFRs
at El Paso Sub

9:50 10:54 Nichols Station to find DC ground on 230 KV.

DC ground is on plant side.

10:01 11:58 San Juan Sw Sta - wiring in revenue panel.

11:00 11:41 PCA Interchange - RTU maintenance

11:02 14:51 Artesia Interchange to Roswell Interchange Z08 - received call
from CVEC informing us that they have all their load off of
their Cottonwood Sub and they were ready for us to open the
MOS 4788. The switch was opened and they will call us when
they are ready for it to be closed back.

CVEC requested MOS 4788 to be closed back.

11:02 SPP released the TLR on the imports.

11:06 Nichols Sta - CA & Mechanism overhaul.

12:15 Riverview Interchange Unit 6 TWR has been released.

22:56 SWPP issued TLR 3A on N/S flow