
Xcel Energy South Control Center Daily Operations Report

Date: 8/31/2008

Out Time: In Time:
(Begin:) (End:)

0:00	10:00	Time error correction "P" started @ 59.98 Hz. TEC ended.
9:10		SPP released TLR to 0 on N/S Flow.
9:39		N/S flow coming up. Called for TLR 3A
10:57		Eddy Co HVDC - on line for schedules.
20:09	20:21	Carriers tested O.K.