

---

---

# *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date: 9/1/2008*

---

---

**Out Time:** *In Time:*  
*(Begin:) (End:)*

2:05 Eddy Co HVDC - Off line no schedules.

10:27 SPP released TLR to 0 on N/S Flow.

11:56 Eddy Co HVDC - on line for schedules.

14:12 15:30 Amerada Hess CO2 - received a low battery alarm and other alarms. Notified DDC to dispatch a man.

There was a fire at the plant. We lost station power which is what gave us the alarms. Amerada Hess is working to get there equipment back in service. Sube is in contact with Amerada Hess personnel. No SPS equipment has been damaged.

15:30 - Station power back on.

17:30 Grapevine Interchange - Received a low nitrogen alarm on the 230/115KV transformer.

19:03 23:15 Import Tie flow coming up. Called for TLR 3B  
N/S flow coming up. Called for TLR 3B

SWPP released TLR on imports to zero @ 2315h