
Xcel Energy South Control Center Daily Operations Report

Date: 12/11/2009

Out Time: *In Time:*
(Begin:) *(End:)*

0:30	7:15	SPP issued TLR 3B on flow gate Temp. 19 - the loss of K16, Harrington to Nichols, will overload K17, Harrington to Nichols. SPP released the TLR to level zero.
	1:00	TEC "C" to end going to 60.00 Hz.
5:50	7:30	SPP issued TLR 3B on temporary flow gate #5 - Loss of K46 (Plant X - Sundown) will overload K42 (Tolk - TUCO). SPP released the TLR to level zero
6:52	18:10	Lamton Interchange to Plant X Sta T28 - H/L for line maintenance. Temporary termination
7:09	18:36	Carlsbad Interchange to White City Z05 - H/L for line maintenance
	7:15	SPP released TLR to level zero on the SPSNORTH_STH flowgate
9:30	12:59	Crosby Co Interchange to SPEC REC Z39 - H/L for SPEC Line maintenance at Robertson feed. TWR terminated.
10:11	11:27	Castro Co Interchange - TWR to clean bushings on sw# 8822 & put TF back in service. Released and term.
10:50	13:00	Eddy Co Interchange - 230/115Kv TF OP ck with TD and TB relays. By pass Disc 4973 will not operate. Tagged in scada. Rly Tech will notify Lub Sub. Station power did not swap. Sube checking on problem. TWR terminated
	12:53	Duval #1 to Potash Junction Interchange Z01 - High side jumpers lifted 1 span from Duval Sub. Line energized back to Duval #1 sub.
13:35	14:03	Grapevine Interchange - TWR to add SF6 gas to 115kv bkr 5J70. Released and term.

Xcel Energy South Control Center Daily Operations Report

Date: 12/11/2009

Out Time: *In Time:*
(Begin:) *(End:)*

13:58 Carlsbad Interchange to Potash Junction Intg V18 - D/L to replace section of wire.
TWR terminated Ckt back in service.

14:56 16:33 Eddy Co Interchange to Roswell Interchange V26 - H/L to replace spans between Sw 3H81 and Sw 3H82 at Tweedy.
TWR terminated

15:47 Amoco Sw Sta to Yoakum Co Interchange K33 - D/L for pole maintenance
TWR terminated and ckt in service

15:55 Nichols Sta - TWR to replace closing coil on 230kv BKR BK20.

16:15 Potter Co Interchange - CA & Mechenism 13.2 BKR 1155.
Released and Term.

17:15 17:41 Deaf Smith Co Interchange - LOP alarm on bkr 2k30, Found A/C breaker tripped in control house and reset.

17:25 17:38 Carriers tested OK

21:17 SPP issued a TLR 3B on Temp 1 - the loss of K11, Deaf Smith to Bushland, will overload V5, Osage to Canyon.