

---

---

## *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date:* 12/12/2009

---

---

*Out Time:* *In Time:*  
*(Begin:)* *(End:)*

<b>0:54</b>	<b>8:32</b>	SPP issued TLR 3B on SPSSPPTIES export flow gate  SPP released the TLR on exports (SPSSPPTIES) at 0832.
<b>7:08</b>	<b>18:08</b>	Lamton Interchange to Plant X Sta T28 - H/L TWR to change arms and poles  Released and Terminated
<b>7:12</b>	<b>18:42</b>	Carlsbad Interchange to White City Z05 - H/L TWR to change arms and poles  Permanently released and terminated
<b>8:25</b>		Artesia Interchange to Roswell Interchange Z08 out from Roswell Interchange to switch 4717 at Orchard Park CVEC. This is to pull new conductor over the top of ckt Z08.  <b>12:20</b> SPP released the TLR on temporary flow gate #1 - Loss of Bushland to Deaf Smith will overload Osage to Canyon.
<b>12:20</b>	<b>19:29</b>	SPP issued a TLR 3B on temporary flowgate #5 - Loss of K46 (Plant X-Sundown) will overload K42 (Tolk-TUCO).
<b>12:55</b>	<b>18:31</b>	SPP issued TLR 3B on SPSSPPTIES export flowgate  18:31 - TLR to "0" on exports.
<b>13:14</b>	<b>13:47</b>	Carlsbad Interchange 115KV BKR out to add SF6 gas. Released and Terminated
<b>14:49</b>	<b>18:07</b>	Lamton Interchange to Springlake Z64 - TWR to change pole