
Xcel Energy South Control Center Daily Operations Report

Date: 12/13/2009

Out Time: In Time:
(Begin:) (End:)

1:17		Deaf Smith Co Interchange - LOP alarm on bkr 2K30 per sube found tripped AC bkr for heater
5:53	14:26	SPP issued a TLR 3A on temporary flowgate #5 - Loss of K46 (Plant X-Sundown) will overload K42 (Tolk-TUCO).
6:27	20:40	SPP issued TLR level 3b on Temp. flowgate #1 - V5 Osage to Canyon overloads with the loss of K11 Bushland to Deaf Smith.
6:27	20:40	SPP issued TLR level 3b on SPSNORTH_STH flow gate
7:25	14:08	Lamton Interchange to Springlake Z64 H/L to change poles. Permanent release and termination.
7:37		Artesia Interchange to Roswell Interchange Z08 D/L from Roswell Intg. To switches 4702 and 4717 to allow for wire pull over line.
9:30	9:49	Performed weekly Mission Mode drill, SPS acting as Situation Room Leader
10:19	12:29	SPP issued TLR 3B on SPSSPPTIES export flow gate TLR level 0
	11:34	Cunningham Sta to Whitten T39 TWR terminated. The isolators South of Monument tap were closed and left in the line.
12:38		Dallam Co Interchange 115 KV capacitor breaker 1J35 tripped. Did not try to close. Requested trip be investigated before we try to close again.
	14:48	Cunningham Sta to Whitten T39 - lift jumpers south of sw 4J57 for work on 838461. Released and Terminated
	18:53	Artesia Interchange to Roswell Interchange Z08 - pulling wire over ckt Temporary Release and Termination