
Xcel Energy South Control Center Daily Operations Report

Date: 12/15/2009

Out Time: *In Time:*
(Begin:) *(End:)*

9:00 **15:30** Hitchland - TWR to replace gear motors in 1R15 and 1R30.
Work complete. TWR terminated.

9:50 **11:19** Kress Interchange - TWR on Capacitor Bkr 9708 to add SF6
gas.

1407 All alarms cleared. Capacitor available.

9:51 **15:23** Carlsbad Interchange to PCA Interchange V61 - D/L for carrier
work. Operate bkr 4975 at PCA.
TWR terminated

11:00 **17:00** Time correction " D" in effect. Time was fast.

11:23 **15:45** Potter Co Interchange - CA Reactor Breaker 1155
Temp. Release and Temp Termination. Will work on this again
tomorrow

11:44 **16:57** Artesia Interchange - North 115/69KV TF out to replace pump
on Low side Bkr. 4620.

TWR terminated

15:12 **15:48** Eddy Co Interchange - TWR on Bkr 4950 replace diode in Bkr
cabinet.

17:00 **17:49** Performed Carrier Tests

17:55 Cunningham Sta to Whitten T39 - Sw 4J87 replaced. Ckt T39
back to normal.
DCC notified that Ward Sub can be fed off ckt.

19:34 Roosevelt Co Interchange - TWR to verify the relays that trip
4H35 and 4995.

Released and terminated.

23:00 SPP issued TLR 3B on flow gate Temp. 19 - the loss of K16,
Harrington to Nichols, will overload K17, Harrington to
Nichols.

23:45 SPP issued a TLR 3A on SPSNORTH_STH flow gate