Xcel Energy South Control Center Daily Operations Report

Date: *12/23/2009*

Out Time: ***(Begin:)***	***In Time:*** ***(End:)***	
4:00		TEC "G" to end and frequency has returned to 60.00 Hz.
	10:13	Jericho WTU to Kirby Sw Sta T52 - AEP put their 138kv line from W. Childress to Hollis, Ok back to normal until around January 4, 2010.
10:26		Nichols Sta - Replacing closing coil on BK20
10:47	**11:25**	Tolk Sta - TK39 add hydralic fluid.
13:55	**13:56**	Higgs to Hobbs Gen T98 - 115Kv ckt open and closed. Hobbs Bkr 4H240 O/C Bkr 4H245 O/C Higgs Bkr 4H155 O/C Bkr 4H175 O/C Fault location 14.5 miles from Higgs 17.2 mile from Hobbs Rain storm in area
15:37		SPP issued a TLR 3A on temporary flowgate #1 - Loss of K11 (Bushland-Deaf Smith) will overload V5 (Osage-Canyon).
16:15		Carriers tested ok.
22:24	**22:24**	Denver City Interchange/Doss to Gaines Co Intg Y98 operated and closed back. Denver City 69KV BKR W720 operated 2 times and closed back.