

---

---

# *Xcel Energy South Control Center Daily Operations Report*

*Date:* 12/26/2009

---

---

*Out Time:* *In Time:*  
*(Begin:)* *(End:)*

1:29	SPP released the TLR on temporary flow gate #19 - Loss of K16 overloads K17.
2:13	5:21 SPP issued a TLR 3B on SPSNORTH_STH
7:53	17:28 TLR 3B on N/S flow.  N/S flow TWR has been released at 1728.
11:52	Tuco Interchange - Scada shows a Gas Detection alarm on the south 230/115kv transformer. This happened yesterday, but it cleared later. Today, it is still in alarm much later. Informed the Texas South Substation COM and Transmission SOC. It was decided, since there is room, to de-energize the transformer and issue a TWR Monday morning to have an oil sample taken and sent to the lab.
23:22	Flowgate Temp. #1 V5 Osage to Canyon overloads with the loss of K11 Bushland to Deaf Smith. TLR level 3b