
Xcel Energy South Control Center Daily Operations Report

Date: 12/28/2009

Out Time: *In Time:*
(Begin:) *(End:)*

	4:34	Temp. flowgate #1 V4 Osage to Canyon overloads with the loss of K11 Bushland to Deaf Smith. TLR level 0
9:16	16:53	Graham Interchange to Justiceburg Corner Z65 is under hot line conditions to allow Big Country REC to change a couple of insulators.
9:16	13:41	Canyon West to Hereford Interchange T03 D/L clearance established between MOD 2910 @ Dawn and open SW 1J74 @ Panda Energy to repair downed static
10:03	10:45	Kress Interchange - Add SF6 gas to cap breaker 9708.
11:35	11:46	Tuco Interchange BRK NK15, TO check micro switches
13:42	14:42	Hereford Interchange Repairs on 2928
14:30	16:30	Hale Co Interchange Low Nitrogen Pressure Alarm. Changed Nitrogen Bottle
17:10	17:33	Performed Carrier Tests