
Xcel Energy South Control Center Daily Operations Report

Date: 12/31/2009

Out Time: *In Time:*
(Begin:) *(End:)*

8:45	9:38	Moore Co Interchange to Potter Co Interchange K31 - D/L to repair static. Released and term.
11:49	13:54	Graham Interchange to Justiceburg Corner Z65 - Big Country REC found problem on their Yancy tap that might have caused operation on Ckt Z61(Lynn bkr 7750). Will move load to Graham Bkr 6F75. No switching needed for SPS
16:00	16:20	Carriers tested OK
23:00		Start Time correction "I" regulate to 59.98 HZ
23:47		SPP issued TLR 3A to take effect at midnight on Temp. flowgate # 19 - K16 Harrington to Nichols overloads with the loss of K17 Harrington to Nichols or vice versa