
Xcel Energy South Control Center Daily Operations Report

Date: 1/1/2010

Out Time: *In Time:*
(Begin:) *(End:)*

0:21	5:33	SPP released TLR to level 0 on Temp. flowgate #1 - V5 Osage to Canyon overloads with the loss of K11 Bushland to Deaf Smith.
	0:34	SPP released TLR on Temp. flowgate #19 to level zero - Loss of one Harrington to Nichols line will overload the other.
6:03	9:29	SPP issued TLR 3B on SPSNORTH_STH flow gate SPP released TLR to level 0.
	10:00	End of TEC "I".
13:56	14:03	Blackhawk Interchange - low gas on 1H70. Dispatched sube. TWR Released and Terminated
14:12	17:25	SPP issued TLR 3B on SPSNORTH_STH Flow gate. SPP released TLR 3 on SPSNORTH_STH
17:30	17:57	Carriers tested.