
Xcel Energy South Control Center Daily Operations Report

Date: 1/3/2010

Out Time: In Time:
(Begin:) (End:)

9:30		Weekly Mission Mode test completed. Hosted by SPS.
11:53	12:04	Turned Carrier Relaying back on, Dalhart 1J75 Moore Co. M995 Nic BK16 Hutch 1K06 Amarillo South 2K85 Swisher 3K02 Pringle 1H30 Harr Fk75 All seem to be working fine now!
17:48	18:25	SWPP issued a TLR 3B on SPSSPPTIES Export flow gate. SWPP released TLR 3B.
19:15	19:48	Carriers tested OK.