
Xcel Energy South Control Center Daily Operations Report

Date: 1/5/2010

Out Time: In Time:
(Begin:) (End:)

7:04		Briscoe to Lockney Rural Y96 - H/L for line maintenance
8:34	8:37	Maddox - Blew fuse in RTU causing all bkr indication to show open at station.
8:38	13:05	Mustang Interchange - de-energize pad mount 13.2 aux. TF.
8:59	14:27	Bowers Interchange to Grapevine Interchange T51 D/L clearance established to make repairs on jumpers Work completed. TWR terminated
9:06	12:10	Roswell Comm RCC6 down except Taylor and Eunice. Comm tech going to Drinkard. Noise on Phone line. RCC6 back up except for Drinkard left off due to noise.. Com tech will report noise on line to phone company.
9:15	12:41	Cunningham Sta - plant operator will place AVR on Cunn. #1 to manual and was instructed to hold vars at current level near zero. AVR back on auto and released order on vars. Notified SWPP
9:27		Other Import limit to zero per SWPP
10:55	13:29	Portales Interchange TWR established to op check bkr 3H135
13:36	13:52	Martin Sw Sta TWR established to add SF6 gas to bkr 2H55
	15:43	Potter Co Interchange Temp. Termination
	16:30	Artesia Interchange to Atoka Interchange Z56 - Notified by CVEC that West Artesia sub is energized now.
17:05	17:19	Performed Carrier Tests
17:40	21:08	SPP issued TLR 3B on SPSSPPTIES exports. SPP released TLR to level zero.
	19:40	MAPCO Enterprise is starting their refrigeration compressor.