

---

---

## *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date: 1/6/2010*

---

---

*Out Time: In Time:*  
*(Begin:) (End:)*

<b>5:30</b>	<b>17:25</b>	Briscoe to Lockney Rural Y96 - H/L re-established for line maintenance.
<b>11:41</b>	<b>12:15</b>	Oasis Interchange - TWR to add SF6 gas to 115kv bkr 3H105. Released and term.
<b>12:28</b>	<b>16:01</b>	Portales Interchange - Bkr 3H140 Op Ck TWR Released and term.
<b>13:12</b>	<b>14:11</b>	Nichols Sta - TWR to Operate sw #B994 to close completely. Released and term.
<b>13:54</b>	<b>21:01</b>	SPP issued a TLR 3B on SPSSPPTIES exports. SPP released TLR 3B on exports.
<b>14:26</b>	<b>15:00</b>	Carlsbad Interchange - Bkr C910 terminal equipment alarm. MW and Mvars readings bad. Alarm cleared and MW and MVAR reading are good.
<b>16:00</b>	<b>16:45</b>	Carriers tested OK