
Xcel Energy South Control Center Daily Operations Report

Date: 1/7/2010

Out Time: *In Time:*
(Begin:) *(End:)*

3:31	6:01	Hale Co Interchange - low oil level on the north 115/69kv transformer. Dispatched a sube to check. The transformer is not in danger. The oil level is just low enough to give the alarm. Sube indicates it is due to be changed out soon.
3:41	15:12	Potash Junction Interchange - low nitrogen on west 115/69kv TF.
3:57	6:37	Nichols Sta - low operating pressure on one of the 230kv breakers. Dispatched sube to check. Normal
5:07		Perryton Interchange - low operating pressure. Dispatched sube to check. Opened Bkr 1H55@ 0928.
6:07		Seven Rivers - low nitrogen alarm on the 115/69kv transformer.
16:10	17:08	Performed Carrier Tests