
Xcel Energy South Control Center Daily Operations Report

Date: 1/8/2010

Out Time: In Time:
(Begin:) (End:)

4:39	6:15	SPP issued TLR 3B on SPSSPPTIES export flow gate 06:15 - SPP released TLR to "0" on exports.
7:46	10:04	Kress Interchange - low nitrogen on west 115/69kv transformer. Normal
7:59	10:15	SPP issued TLR 3B on SPS/SPP Exports.
9:32	12:59	Moore Co Interchange H/L clearance established to re-attach deadend shoe. Work completed. TWR terminated.
11:58	15:31	TLR 3B issued on the exports. TLR to zero.
13:20	22:01	Eddy Co HVDC - on line for schedules. Eddy Co HVDC off line - no schedules. Oil pumps were left on, for now.
14:59	15:06	Texas Co Interchange - Investigate problems with Cap Breaker OH15.
16:00	16:15	Perform carrier test.