
Xcel Energy South Control Center Daily Operations Report

Date: 1/10/2010

Out Time: ***In Time:***
(Begin:) ***(End:)***

9:23		Harrington Sta - plant reported AVR on auto and TO notified plant to take vars to outside as soon as unit is capable.
11:38		Harrington Sta Unit 2 is back offline to perform another balance shot.
22:06	23:41	Tuco Interchange to Oklaunion (PSO) J01 Oklaunion end of the line tripped. Cause is unknown at this time. Lowered inport limits to 165 and exports to 346
23:48		Other Olkaunion - J1 back in and normal released imports to - 594