
Xcel Energy South Control Center Daily Operations Report

Date: 1/13/2010

Out Time: In Time:
(Begin:) (End:)

2:59	4:15	Kingsmill Interchange - low operating pressure on 2840. Dispatched sube to check.
3:19	7:27	SPP issued a TLR 3B on flow gate Temp 5 - the loss of K46, Plant X to Sundown, will overload K42, Tolc to Tuco
7:08	17:59	Briscoe to Lockney Rural Y96 - H/L for line maintenance. Temp release and term.
9:24		Cunningham Sta to Eddy Co Interchange K23 - D/L to change arms and poles.
10:24	14:29	Hitchland - CA breaker 1R25
11:56	14:47	Potash Junction Interchange - OP check 115kv bkr 3H245. Released and term.
14:20	14:55	Moore Co Interchange to Potter Co Interchange K31 is under hot line conditions to repair down guy wire.
14:59	14:59	Hutchinson Co Interchange to Nichols Sta K06 - Hutch breaker 1K06 appeared to miss op. The Nichols end did not operate. The event appeared to be real as the MW flow went to zero.
17:12		Carrier tested good.