
Xcel Energy South Control Center Daily Operations Report

Date: 1/18/2010

Out Time: ***In Time:***
(Begin:) ***(End:)***

7:05	17:46	Briscoe to Lockney Rural Y96 is under hot line conditions for line maintenance.
9:59		Tuco Interchange SVC is out of service for annual maintenance on the SVC 230 KV Transformer.
10:15		Roosevelt Co Interchange 4K63 replace Interrupters and insulators.
11:13		Martin Sw Sta to Wind Farm new owner to op check wind farm and test relays.
16:55		Carriers tested good.
	18:58	Mustang Interchange - checkout for the Yoakum line terminal