
Xcel Energy South Control Center Daily Operations Report

Date: 1/19/2010

Out Time: In Time:
(Begin:) (End:)

- 1:58** **1:58** Finney Sw Sta to Hitchland J07 - This line operated 1 time and closed back. 345KV breakers 1R25 and 1R30 at Hitchland opened up. Breaker OR70 at Finney opened up (OR65 is out of service right now). 1R25 at Hitchland and OR70 at Finney reclosed automatically. 1R30 was closed by supervisory. Fault location given by SCADA is 2.1 miles from Finney and 110.2 miles from Hitchland.
- 7:25** **16:20** Briscoe to Lockney Rural Y96 is under hot line conditions for line maintenance. Permanet release.
- 7:36** **10:10** Cunningham Sta to San Andres LCEC V98 is under hot line conditions for line maintenance.
- 8:06** **16:44** Maddox - V90 and V83 are under hot line conditions for line maintenance.
- 9:15** Mustang Interchange - East 230 KV Bus is out of service to reconstruct this end of the Bus.
- 12:00** Norton 115KV Bus voltage bouncing @ 2 KV. Notified the wind farm and they checked their equipment. Their equipment was working correctly. I expressed my concern that my voltage needed to be higher at the source, and they said they had no problem with me raising the voltage at Curry.
- 14:56** Martin Sw Sta Recloser on line feeding Pantex is turned off till check out. System tag 7258.
- 15:29** Roosevelt Co Interchange 4K63 TWR work completed
- 16:02** Briscoe to Lockney Rural Y96 TWR 837784 has been released permanently.
- 16:35** Carriers tests good.
- 21:51** SPP issued TLR 3A on SPSNORTH_STH
- 21:51** SPP issued TLR 3A on Temp. flowgate #1 - V5 Osage to Canyon overloads for the loss of K11 Bushland to Deaf Smith.