
Xcel Energy South Control Center Daily Operations Report

Date: 1/22/2010

Out Time: In Time:
(Begin:) (End:)

6:13 SPP released the TLR 3B on flow gate Temp 1 - the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon

6:25 14:21 SPP issued a TLR 3B on temporary flow gate #5 - Loss of K46 (Plant X-Sumdown) will overload K42 (Tolk-TUCO).

10:01 13:28 Jones Sta Inspecting disconnect JK12 and associated equipment after the fault yesterday.

10:55 Notified SPP that we are under a Wind Advisory thru 18:00.

12:29 SPP issued a TLR 3B on temporary flow gate # 1 - Loss of K11 (Bushland-Deaf Smith) will overload V5 (Osage-Canyon).

14:09 Finney - turned recloser back on for 0R67 & 0R77.

14:52 15:11 Kirby Sw Sta TWR to add SF-6 gas to 5J80.

18:43 19:30 Bailey Co Interchange to Lamb Co Interchange Y80 - bkr 3850 O/C/O/C/O/C/O tried 1 time by supervisory. Locked open. W. Littlefield, Amherst, Sudan Rural and Lamb REC Sandhill out of lights.
Storms in area.
Lamb REC will patrol their lines.
1914 opened Sw 3755
1915 Closed Lamb Bkr 3850 to test line section. It held. W. Littlefield and Amhurst back on.
1923 opened sw 8810 on tap to Lamb REC Sandhill.
1930 closed Sw 3755 bkr 3850 held and Sudan Rural back on.
1940 Lamb REC reported cross arm fell on their line.
2042 Sw 8810 closed (Sandhill) at Lamb Rec request. Bkr held at Lamb.

20:35 20:35 Denver City Interchange/Doss to Gaines Co Intg Y98 - Bkr W720 O/C
storms in area.
No fault location

Xcel Energy South Control Center Daily Operations Report

Date: 1/22/2010

Out Time: ***In Time:***
(Begin:) ***(End:)***

20:38	20:38	Denver City Interchange/Doss to Gaines Co Intg Y98 - Denver Bkr W720 O/C/O/C feeds LEA Rec KCM storms in area. 2nd operation.
20:50	20:50	Denver City Interchange/Doss to Gaines Co Intg Y98 - Denver Bkr W720 O/C/O/C Feeds LEA CO KCM storms in area. 3rd operation. LEA having operations on their distribution.
	21:39	SPP released the TLR 3 on flow gate Temp 1 - the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon
22:20		SPP issued TLR 3B on flow gate Temp 1 - the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon