
Xcel Energy South Control Center Daily Operations Report

Date: 1/24/2010

Out Time: In Time:
(Begin:) (End:)

	4:25	SPP released TLR to level zero on Temp. #1 flowgate. the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon
7:03	11:11	SPP issued TLR 3B on flow gate Temp 1 - the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon
9:00	18:00	Time correction "D" in effect. Time was fast.
9:41		Completed weekly Mission Mode test.
	11:51	Cochran Co/Hockley Co Intg to Terry Co Intg Z25 - terminate dead line TWR
12:28		SPP released TLR 3B on flow gate Temp 1 - the loss of K11, Bushland to Deaf Smith, will overload V5, Osage to Canyon
20:30	20:45	Performed carrier test.
23:35	0:16	Blackhawk Interchange - 1H75 has LOP alarm. Notified DDC to send a sube. Sube corrected problem. Alarm cleared.