
Xcel Energy South Control Center Daily Operations Report

Date: 1/26/2010

Out Time: In Time:
(Begin:) (End:)

9:07	13:18	Crosby Co Interchange to SPEC REC Z39 H/L established for SPEC to install a mobile sub at their Caprock Sub.
16:00	16:17	Martin Sw Sta - Adding SF6 gas to breaker 2H55
17:14		Carriers tested good.