
Xcel Energy South Control Center Daily Operations Report

Date: 1/27/2010

Out Time: In Time:
(Begin:) (End:)

9:06	15:05	Bowers Interchange to Kingsmill Interchange Y60. TWR to repair PT Fuse 2805
11:36	13:01	Moore Co Interchange to Potter Co Interchange K31 out to re-hang static bar
13:22	17:03	Plant X Sta 230 KV breaker XK31 performing operational checks.
	16:17	Happy Interchange to Kress Interchange T67 - Closed bkr 9970 at Happy Intg for winter storm.
	17:01	Cunningham Sta to Eddy Co Interchange K23 took a temporary release and termination due to potential winter storm in the area tonight and tomorrow.
18:17	18:28	Carriers tested O.K.
	18:40	East Plant Interchange to Osage Sw Sta V43 - TWR to isolate section between Pierce St Sub and Osage to perform line maintenance. Temp release and term.
	18:46	East Plant Intg to Osage Sw Sta/Randall Co Intg V4 - TWR to isolate line section between East Plant and Manhattan sub tap to perform line maintenance. Temp release and term.
	21:53	Swisher Co Interchange - Replace control valve and CA 115kv bkr 8943. Temp release and term.