
Xcel Energy South Control Center Daily Operations Report

Date: 2/3/2010

Out Time: In Time:
(Begin:) (End:)

0:21		SPP RC issued 3B IDC TLR on SPPSPSTIES import flow gate
0:45	1:05	Carriers tested OK
	8:18	Swisher Co Interchange TWR 839517 on breaker 8943 has been released.
11:50	17:01	Potash Junction Interchange - TWR Op checking BKR 4920
	13:46	Tuco Interchange to Oklaunion (PSO) J01 - PSO closed up their Oklaunion end. SPPSPSTIES import flow gate back to 594 MW & N/S flow back to 800 MW. Flowgate 5247 released.
	14:37	Potter Co Interchange BKR 2K35 back in service on temporary termination. May work again tomorrow if weather permits.
17:18		Carriers tested good.