

---

---

# *Xcel Energy South Control Center Daily Operations Report*

*Date: 2/6/2010*

---

---

*Out Time: In Time:*  
*(Begin:) (End:)*

**5:33      15:37** Lamar HVDC - 05:33 Tripped no schedules. PSCO calling out personnel to check before putting back on. Posted OPS1. Notified SPP RC. Posted Oasis #73818

Lamar HVDC is available at 15:37

**14:45** Harrington Sta 230KV disc FK51 replaced.

**15:25** Harrington Sta 230KV disc FK49 has been replaced.

**15:45** Harrington Sta replace 230KV transfer switch FK52.

**18:05      18:28** Carriers tested.  
TUCO-Indiana, Plant X-Lamb, & Roosevelt-Curry are still turned off.