
Xcel Energy South Control Center Daily Operations Report

Date: 2/8/2010

Out Time: In Time:
(Begin:) (End:)

8:51 Cunningham Sta to Eddy Co Interchange K23 is out of service for line maintenance.

10:48 Denver City Interchange - North 115/69 KV Trf is out of service to repair LTC.

11:00 **15:00** Denver City Interchange - Op Checking Breaker W980.

11:19 Jones Sta - established TWR to CA Breaker JK15

12:55 **14:55** Lamton Interchange - TWR to CA Breaker 7H90

14:46 **15:48** Yoakum Co Interchange - Transfer bus is unavailable under TWR to repair transfer switch 6K57.

15:54 **18:29** SPP issued TLR 3 B on SPPSPSTIES import flow gate

SPP released TLR to zero @ 1829.

16:41 East Plant Interchange to Osage Sw Sta V43 - permanent release on TWR for arm and pole change out. (Line has been in service after a temporary release last week)

16:41 East Plant Intg to Osage Sw Sta/Randall Co Intg V4 - Permanent release on TWR for arm and pole changes. (Line has been in service after a temporary release since last week)

16:45 Carriers test good.